



**Drinking-Water System Number:** 260022152  
**Drinking-Water System Name:** Breslau Distribution System  
**Drinking-Water System Owner:** Township of Woolwich  
**Drinking-Water System Category:** Large Municipal Residential  
**Period being reported:** January 1, 2022– December 31, 2022

**For Large Municipal Residential Systems:**

**Does your Drinking-Water System serve more than 10,000 people?**

- Yes
- No

**Is your annual report available to the public at no charge on a website on the internet?**

- Yes
- No

**Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:**

- Available by calling Infrastructure Services at 519-669-6043
- [www.woolwich.ca](http://www.woolwich.ca)

**Are there any Designated Facilities serviced by your system, and is a copy of your annual report provided to all Facilities?**

Yes, there are five Designated Facilities, which receives a copy of this report.

**1. List all Drinking-Water Systems (if any), which receive all their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N/A	

**2. Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all its drinking water?**

- Yes
- No

**3. Indicate how you notified system users that your annual report is available and is free of charge.**

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request

**4. Describe your Drinking-Water System**

The Breslau Distribution System receives water from the Region of Waterloo Well Supply, which is part of the Urban Integrated System (UIS). The Urban Integrated System (UIS) is owned and operated by the Regional Municipality of Waterloo. The UIS does include water storage facilities, including elevated storage, chlorine and pressure boosting facilities and zone isolation and regulating valves. Although this infrastructure is under care and control of the Region, operations directly impact Breslau Distribution system.

**Drinking Water Systems Regulations**

(PIBS 4435e01)



The Township of Woolwich owns and operates the distribution system including the pipes, valves, and residential meters, this includes 1577 service connections in three subdivisions, has a population of approximately 3788, with 155 hydrants.

**5. List all water treatment chemicals used over this reporting period**

Water treatment is the responsibility of the Region of Waterloo. The Region reports all the treatment chemicals used via their annual Water Quality Reports. The Township of Woolwich disinfects all parts, material and pipe during new installation and repair.

**6. Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**7. Please provide a brief description and a breakdown of monetary expenses incurred**

Not applicable. No significant expense incurred.

**8. Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
2022-06-21	Total Coliform	Present	Present/Absent	Flushed and resampled at the adverse site, and upstream	2022-06-22
2022-06-22	Total Coliform	Present	Present/Absent	Flushed and resampled at the adverse site, upstream and downstream	2022-06-23
2022-06-23	Total Coliform	Present	Present/Absent	Flushed and resampled at the adverse site, upstream and downstream	2022-06-24
2022-07-27	Total Coliform	Present	Present/Absent	Flushed and resampled at the adverse site, upstream and downstream	2022-07-28
2022-08-03	Total Coliform	Present	Present/Absent	Flushed and resampled at the adverse site, upstream and downstream	2022-08-04
2022-08-31	Total Coliform	Present	Present/Absent	Flushed and resampled at the adverse site, upstream and downstream	2022-09-01

**9. Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**



Sample Source	Number of Samples	Range of E. Coli or Fecal Results (min) - (max)	Range of Total Coliform Results (min) - (max)	Number of HPC Samples	Range of HPC Results (min) - (max)
Distribution	246	A	A-P	87	0-21 (CFU/mL)

**10. Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min) - (max)	Unit of Measure
Township Chlorine Combined	374	0.45 – 1.62	mg/L

**11. Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

**12. Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Number of Samples	Result Value Range (min-max)	Unit of Measure	Number of Exceedances
Alkalinity	4	278 - 311	mg/L	None
pH	4	6.71 – 7.1	pH	None

**13. Summary of lead testing under Schedule 15.1 during this reporting period:**

Location Type	Number of Samples	Range of Lead Results (min) – (max)	Unit of Measure	Number of Exceedances
Plumbing	Not Required		ug/L	None
Distribution	4	<0.200	ug/L	None

**14. Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Number of Samples	Result Value	Unit of Measure	Number of Exceedances
Haloacetic Acids (HAA) (NOTE: annual average)	4	<8.58	ug/L	None
THM (NOTE: annual average)	4	25.625	ug/L	None

**15. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			