



Drinking-Water System Number: 260002798  
 Drinking-Water System Name: St. Jacobs/Elmira Distribution System  
 Drinking-Water System Owner: Township of Woolwich  
 Drinking-Water System Category: Large Municipal Residential  
 Period being reported: January 1, 2022 – December 31, 2022

**For Large Municipal Residential Systems:**

**Does your Drinking-Water System serve more than 10,000 people?**

- Yes
- No

**Is your annual report available to the public at no charge on a website on the internet?**

- Yes
- No

**Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:**

- Available by calling Infrastructure Services at 519-669-6041
- [www.woolwich.ca](http://www.woolwich.ca)

**Are there any Designated Facilities serviced by your system, and is a copy of your annual report provided to all Facilities?**

Yes, there are 19 Designated Facilities, and they are all provided a copy of the annual report.

**1. List all Drinking-Water Systems (if any), which receive all their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
None	N/A

**2. Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all its drinking water?**

- Yes
- No

**3. Indicate how you notified system users that your annual report is available and is free of charge.**

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request

**4. Describe your Drinking-Water System**

The Woolwich North Distribution System receives water from the Region of Waterloo Well Supply, which is part of the Urban Integrated System (UIS). The Urban Integrated System (UIS) is owned and operated by the Regional Municipality of Waterloo. The UIS does include water storage facilities, including elevated storage, chlorine and pressure boosting facilities and zone

isolation and regulating valves. Although this infrastructure is under care and control of the Region, operations directly impacts Woolwich North Distribution system.

The Township of Woolwich owns and operates the Woolwich North Distribution System, including pipes, valves and residential meters. The Woolwich North distribution system services a population of approximately 15106 people with about 5088 residential service connections, with approximately 573 hydrants

**5. List all water treatment chemicals used over this reporting period**

Water treatment is the responsibility of the Region of Waterloo. The Region of Waterloo reports all the treatment chemicals used via their annual Water Quality Reports for the Integrated Urban System. The Township of Woolwich disinfects all parts, material and pipe during new installation and repair.

**6. Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**7. Please provide a brief description and a breakdown of monetary expenses incurred**

Not applicable. No significant expense incurred.

**8. Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
2022-03-01	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-03-02
2022-06-22	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-06-23
2022-06-29	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-06-30
2022-07-20	Total Coliform	P	A - P	Flushed and resample- upstream and source sampled (no downstream)	2022-07-21
2022-07-25	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-07-26
2022-07-27	Total Coliform	P	A - P	Flushed and resample- upstream and source sampled (no downstream)	2022-07-28
2022-08-04	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-08-05
2022-08-04	Total Coliform	P	A - P	Flushed and resample- upstream and source sampled (no downstream)	2022-08-05
2022-08-10	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-08-11

2022-08-11	Total Coliform	P	A - P	Flushed and resample- upstream and source sampled (no downstream)	2022-08-12
2022-08-17	Combined Chlorine	<0.25 Combined & <0.05 Free	Mg/L	Flushed and resample- upstream, downstream and source sampled	2022-08-17
2022-08-17	Total Coliform	P	A - P	Flushed and resample- upstream and source sampled (no downstream)	2022-08-18
2022-08-17	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-08-18
2022-09-07	Total Coliform	P	A - P	Flushed and resample- upstream and source sampled (no downstream)	2022-09-08
2022-09-13	Total Coliform	P	A - P	Flushed and resample- upstream, downstream and source sampled	2022-09-14

**9. Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

Sample Source	Number of Samples	Range of E. Coli or Fecal Results (min) - (max)	Range of Total Coliform Results (min) - (max)	Number of HPC Samples	Range of HPC Results (min) - (max)
Distribution	439	A	A - P	156	0 – 390 (CFU/mL)

**10. Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min) - (max)	Unit of Measure
Township Chlorine Combined	966	0.45 – 1.53	mg/L

**11. Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

**12. Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Number of Samples	Result Value Range (min-max)	Unit of Measure	Exceedance
Alkalinity	15	218 - 278	mg/L	None
pH	33	6.7 -7.8	pH	None

**13. Summary of lead testing under Schedule 15.1 during this reporting period:**

Location Type	Number of Samples	Range of Lead Results (min) – (max)	Unit of Measure	Number of Exceedances
Plumbing	32	<0.200 – 9.19	ug/L	None
Distribution	11	<0.200 – 2.05	ug/L	None



**14. Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Number of Samples	Result Value	Unit of Measure	Number of Exceedances
Haloacetic Acids (HAA) (NOTE: annual average)	20	<6.084	ug/L	None
THM (NOTE: annual average)	12	18.035	ug/L	None

**15. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			