



**Drinking-Water System Number:** 260002499  
**Drinking-Water System Name:** Conestogo Plains Distribution System  
**Drinking-Water System Owner:** Township of Woolwich  
**Drinking-Water System Category:** Large Municipal Residential  
**Period being reported:** January 1, 2018 – December 31, 2018

**For Large Municipal Residential Systems:**

**Does your Drinking-Water System serve more than 10,000 people?**

- Yes
- No

**Is your annual report available to the public at no charge on a website on the internet?**

- Yes
- No

**Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:**

- Available by calling Engineering & Planning Services at 519-669-6041
- [www.woolwich.ca](http://www.woolwich.ca)

**Are there any Designated Facilities serviced by your system, and is a copy of your annual report provided to all Facilities?**

Yes, there are two Designated Facilities, both of which receive a copy of this report.

**1. List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number

**2. Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

- Yes
- No

**3. Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request



**4. Describe your Drinking-Water System**

The Township of Woolwich owns and operates the Conestogo Plains distribution system, including pipes, valves and residential meters. The distribution system has approximately 178 residential service connections with a population of approximately 534. The Conestogo Plains distribution system does not serve any industrial properties. There are 25 hydrants on the system. New construction included service laterals for all properties fronting Sawmill Rd, this added 63 services to this system, previous to this construction there were 115 services on this system. The construction also added 8 hydrants.

The Conestogo Plains distribution system receives water from the Conestogo Plains Well System, and is owned and operated by the Region of Waterloo.

The Township of Woolwich’s distribution system does not provide treatment to the water; therefore, there is no chlorine boosting, ultraviolet (UV) irradiation, secondary disinfection, and pressure boosting or pressure control within the control of the water distribution system.

**5. List all water treatment chemicals used over this reporting period**

Water treatment is the responsibility of the Region of Waterloo. The Region of Waterloo reports all the treatment chemicals used via their annual Water Quality Reports. The Township of Woolwich disinfects all parts, material and pipe during new installation and repair.

**6. Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**7. Please provide a brief description and a breakdown of monetary expenses incurred**

**8. Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
No adverse results for the 2018 reporting period.					

**9. Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

Sample Source	Number of Samples	Range of E.Coli Or Fecal Results (min) - (max)	Range of Total Coliform Results (min) - (max)	Number of HPC Samples	Range of HPC Results (min) - (max)
Distribution	118	A	A	46	0 – 2 (CFU/mL)

**10. Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**



	Number of Grab Samples	Range of Results (min) - (max)	Unit of Measure
Township Chlorine Combined	422	0.55-1.76	mg/L

**11. Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

**12. Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Number of Samples	Result Value Range (min-max)	Unit of Measure	Number of Exceedances
Alkalinity	1	226	mg/L	0
pH	1	7.1	pH	0

**13. Summary of lead testing under Schedule 15.1 during this reporting period:**

Location Type	Number of Samples	Range of Lead Results (min) – (max)	Unit of Measure	Number of Exceedances
Plumbing	Not Required		ug/L	0
Distribution	1	0.338	ug/L	0

**14. Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Number of Samples	Result Value	Unit of Measure	Number of Exceedances
Haloacetic Acids (HAA) (NOTE: annual average)	4	1.7	ug/L	None
THM (NOTE: annual average)	4	8.23	ug/L	None

**15. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample