



## Woolwich Fire Department Mobile Food Vehicle Self-Inspection Checklist

		Yes	No	N/A
<b>GENERAL</b>				
Ontario Regulation 213/07 Fire Protection and Prevention Act, 1997 Fire Code Division B Part 2 & Part 6				
1	All documents have the name of the business, name of the owner of the vehicle and the name of the operator of the vehicle and are in your possession.			
2	Contact phone numbers and emails if you need to be contacted for any matter relating to fire safety are readily available.			
3	A clear description of where the mobile food/beverage truck will be located.			
<b>Comments</b>				
<b>APPLIANCES</b>				
Ontario Regulation 213/07 Fire Protection and Prevention Act, 1997 Fire Code Division B Part 2.4				
4	Must possess a current certificate from TSSA that an inspection has been carried out and that the appliances and vehicle are acceptable to be operated.			
5	The appliance serial number is in a visible location and legible for inspectors.			
6	The vehicle appliance manufacturer name is clearly visible and legible for inspectors.			
7	Vehicle must contain a charged portable fire extinguisher of a 20BC or higher rating			
7a	Extinguisher has been serviced in the past 12 months by a portable extinguisher company			
8	Vehicle must contain a "Class K" type of portable extinguisher that is a 40BC rating			
8a	Extinguisher has been serviced in the past 12 months by a portable extinguisher company			
9	The venting equipment for grills, fryers, burners or other open cooking appliances is installed to NFPA 96 – Standard for Ventilation Control and Fire Protection of Cooking Operations.			
10	Fixed extinguishing systems installed for grills, fryers, burners or other open cooking appliances are to NFPA 96 – Standard for Ventilation Control and Fire Protection of Cooking Operations.			
10a	Inspection tag is affixed to the system showing the last inspection date and that the inspection was conducted within the last 6 months.			
11	Cooking appliances have been cleaned and are free of grease build-up or food remnants			
12	Owner, operator or other workers on these mobile vehicles are knowledgeable in the use of portable fire extinguishers and of manually discharging the fixed extinguish system if it fails to discharge.			
<b>Comments</b>				



## Woolwich Fire Department Mobile Food Vehicle Self-Inspection Checklist

	Yes	No	N/A
I/We the individual completing this survey hereby acknowledge and declare that; I/We have read and understood Sections 1 to 6 of Division B of the Ontario Fire Code as written in Ontario Regulation 213/07 made under the Fire Protection and Prevention Act, 1997; the information contained in this form is true and complete to the best of my/our knowledge, and that failure to provide complete or accurate information may delay the licensing process;			

Name \_\_\_\_\_ Signature \_\_\_\_\_

Business Name \_\_\_\_\_ Business Address \_\_\_\_\_

Business Phone \_\_\_\_\_

This self-inspection checklist is excerpts from the Ontario Fire Code and does not imply or limit the responsibility of the owner or owner's representative to carry out all the provisions of the Ontario Fire Code. A copy of this inspection shall be forwarded to The Woolwich Fire Department via one of the following:

**By E-mail:** [daldous@woolwich.ca](mailto:daldous@woolwich.ca)

**By Fax:** 519-664-2018

**or by mail:** Woolwich Fire Department, 24 Church Street West, Elmira, ON N3B 2Z6

If you have any questions, please direct them to:

**Woolwich Fire Department  
519-664-2887**

Personal information contained on this form is collected under the authority of the Municipal Act, 2001, and will be retained in your property file as proof of inspection. Any questions about the collection and use of this personal information may be directed to the Township of Woolwich Clerk at 24 Church Street W, PO Box 158, Elmira, ON N3B 2Z6 or 519-669-1647 or 1-877-969-0094.